

Itahue / Folder / 7SA612_A4_15-02-2025_Var

MLFB: 7SA61255AE217PR4
Parameter set version: V04.61.06
Device path: C:\Siemens\Digsi4\D4PROJ\Itahue\P7DI\GV\ST\000000004
Author:
Creation date: 24.04.25 15:01:36
Last modified: 24.04.25 15:02:13
Operating mode: Offline
Comment:
Setting values in: Secondary value description

PRINT - CONTENTS

1 Indications 2
1.1 Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA6... 2

1 Indications

1.1 Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612

Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612

Number	Indication	Value	Date and time	Cause
02783	AR: Auto-reclose is blocked	ON	15.02.2025 18:12:29.411	Spontaneous Com.Issued=AutoLocal
02975	SYNC voltage Usy2 < U> (P.3503)	OFF	15.02.2025 18:12:28.913	Spontaneous Com.Issued=AutoLocal
02941	Synchronization is running	OFF	15.02.2025 18:12:28.913	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	154 - OFF	15.02.2025 18:12:28.911	Spontaneous Com.Issued=AutoLocal
00536	Relay Definitive TRIP	ON	15.02.2025 18:12:28.911	Spontaneous Com.Issued=AutoLocal
02935	Synchro-check supervision time expired	ON	15.02.2025 18:12:28.911	Spontaneous Com.Issued=AutoLocal
02975	SYNC voltage Usy2 < U> (P.3503)	ON	15.02.2025 18:12:27.913	Spontaneous Com.Issued=AutoLocal
02941	Synchronization is running	ON	15.02.2025 18:12:27.913	Spontaneous Com.Issued=AutoLocal
04006	>Dis.Tele. Carrier RECEPTION Channel 1	OFF	15.02.2025 18:12:27.438	Spontaneous Com.Issued=AutoLocal
	52A4 CLOSE	OFF	15.02.2025 18:12:27.296	Spontaneous
04006	>Dis.Tele. Carrier RECEPTION Channel 1	ON	15.02.2025 18:12:27.265	Spontaneous Com.Issued=AutoLocal
04056	Dis. Telep. Carrier SEND signal	ON	15.02.2025 18:12:27.252	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	154 - ON	15.02.2025 18:12:27.251	Spontaneous Com.Issued=AutoLocal
00060	Reset LED	ON	22.10.2024 19:11:04.432	Spontaneous Com.Issued=AutoLocal
	Reset LED	ON	22.10.2024 19:11:04.432	Spontaneous Command Issued=Local
00068	Clock Synchronization Error	OFF	22.10.2024 18:09:31.995	Spontaneous Com.Issued=AutoLocal
00060	Reset LED	ON	22.10.2024 18:07:44.645	Spontaneous Com.Issued=AutoLocal
	Reset LED	ON	22.10.2024 18:07:44.645	Control Issued Command Issued=DIGSI
00051	Device is Operational and Protecting	ON	22.10.2024 18:07:29.616	Spontaneous Com.Issued=AutoLocal
	52A4 CLOSE	ON	22.10.2024 18:07:28.319	Spontaneous
00067	Resume	ON	22.10.2024 18:07:28.290	Spontaneous Com.Issued=AutoLocal
02783	AR: Auto-reclose is blocked	ON	22.10.2024 18:07:28.313	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	22.10.2024 18:07:28.308	Spontaneous Com.Issued=AutoLocal
00052	At Least 1 Protection Funct. is Active	ON	22.10.2024 18:07:28.318	Spontaneous Com.Issued=AutoLocal



Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612 (3)

Number	Indication	Value	Date and time	Cause
00070	Setting calculation is running	ON	22.10.2024 18:07:13.110	Spontaneous Com.Issued=AutoLocal
00068	Clock Synchronization Error	OFF	22.10.2024 16:58:38.994	Spontaneous Com.Issued=AutoLocal
00060	Reset LED	ON	22.10.2024 16:56:49.894	Spontaneous Com.Issued=AutoLocal
	Reset LED	ON	22.10.2024 16:56:49.894	Control Issued Command Issued=DIGSI
00051	Device is Operational and Protecting	ON	22.10.2024 16:56:36.509	Spontaneous Com.Issued=AutoLocal
	52A4 CLOSE	ON	22.10.2024 16:56:35.213	Spontaneous
00067	Resume	ON	22.10.2024 16:56:35.184	Spontaneous Com.Issued=AutoLocal
02783	AR: Auto-reclose is blocked	ON	22.10.2024 16:56:35.207	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	22.10.2024 16:56:35.202	Spontaneous Com.Issued=AutoLocal
00052	At Least 1 Protection Funct. is Active	ON	22.10.2024 16:56:35.212	Spontaneous Com.Issued=AutoLocal
	52A4 CLOSE	ON	22.10.2024 16:56:33.413	Spontaneous
00067	Resume	ON	22.10.2024 16:56:33.382	Spontaneous Com.Issued=AutoLocal
02783	AR: Auto-reclose is blocked	ON	22.10.2024 16:56:33.407	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	22.10.2024 16:56:33.403	Spontaneous Com.Issued=AutoLocal
00052	At Least 1 Protection Funct. is Active	ON	22.10.2024 16:56:33.412	Spontaneous Com.Issued=AutoLocal
00070	Setting calculation is running	ON	22.10.2024 16:56:18.120	Spontaneous Com.Issued=AutoLocal
00060	Reset LED	ON	22.10.2024 16:41:21.432	Spontaneous Com.Issued=AutoLocal
	Reset LED	ON	22.10.2024 16:41:21.432	Spontaneous Command Issued=Local
00060	Reset LED	ON	08.10.2024 17:29:02.497	Spontaneous Com.Issued=AutoLocal
	Reset LED	ON	08.10.2024 17:29:02.497	Spontaneous Command Issued=Local
00301	Power System fault	153 - OFF	07.10.2024 18:32:54.135	Spontaneous Com.Issued=AutoLocal
04056	Dis. Telep. Carrier SEND signal	ON	07.10.2024 18:32:54.070	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	153 - ON	07.10.2024 18:32:54.070	Spontaneous Com.Issued=AutoLocal
00060	Reset LED	ON	06.09.2024 12:57:45.071	Spontaneous Com.Issued=AutoLocal
	Reset LED	ON	06.09.2024 12:57:45.071	Spontaneous Command Issued=Local
02932	Synchro-check is BLOCKED	OFF	02.08.2024 04:13:57.073	Spontaneous Com.Issued=AutoLocal



Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612 (5)

Number	Indication	Value	Date and time	Cause
07152	Backup O/C is BLOCKED	ON	02.08.2024 04:13:57.073	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.08.2024 04:13:57.073	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.08.2024 04:13:57.073	Spontaneous Com.Issued=AutoLocal
00170	VT Fuse Failure (alarm instantaneous)	OFF	02.08.2024 04:13:57.073	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	ON	02.08.2024 04:13:57.048	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.08.2024 04:13:57.048	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.08.2024 04:13:57.048	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.08.2024 04:13:57.048	Spontaneous Com.Issued=AutoLocal
00170	VT Fuse Failure (alarm instantaneous)	ON	02.08.2024 04:13:57.048	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	OFF	02.08.2024 04:13:56.041	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.08.2024 04:13:56.041	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.08.2024 04:13:56.041	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.08.2024 04:13:56.041	Spontaneous Com.Issued=AutoLocal
00170	VT Fuse Failure (alarm instantaneous)	OFF	02.08.2024 04:13:56.041	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	ON	02.08.2024 04:13:56.016	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.08.2024 04:13:56.016	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.08.2024 04:13:56.016	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.08.2024 04:13:56.016	Spontaneous Com.Issued=AutoLocal
00170	VT Fuse Failure (alarm instantaneous)	ON	02.08.2024 04:13:56.016	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	OFF	02.08.2024 04:13:56.006	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.08.2024 04:13:56.006	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.08.2024 04:13:56.006	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.08.2024 04:13:56.006	Spontaneous Com.Issued=AutoLocal
00170	VT Fuse Failure (alarm instantaneous)	OFF	02.08.2024 04:13:56.006	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	ON	02.08.2024 04:13:55.976	Spontaneous Com.Issued=AutoLocal



State

Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612 (7)

Number	Indication	Value	Date and time	Cause
07152	Backup O/C is BLOCKED	OFF	02.08.2024 04:13:55.976	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.08.2024 04:13:55.976	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.08.2024 04:13:55.976	Spontaneous Com.Issued=AutoLocal
00170	VT Fuse Failure (alarm instantaneous)	ON	02.08.2024 04:13:55.976	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	152 - OFF	02.08.2024 02:28:49.247	Spontaneous Com.Issued=AutoLocal
04056	Dis. Telep. Carrier SEND signal	ON	02.08.2024 02:28:49.206	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	152 - ON	02.08.2024 02:28:49.206	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	151 - OFF	02.08.2024 02:24:50.887	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	151 - ON	02.08.2024 02:24:50.838	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	OFF	02.06.2024 06:21:57.762	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.06.2024 06:21:57.762	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.06.2024 06:21:57.762	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.06.2024 06:21:57.762	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	OFF	02.06.2024 06:21:57.762	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	ON	02.06.2024 05:50:42.334	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.06.2024 05:50:42.334	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.06.2024 05:50:42.334	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.06.2024 05:50:42.334	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	ON	02.06.2024 05:50:42.334	Spontaneous Com.Issued=AutoLocal
02783	AR: Auto-reclose is blocked	OFF	02.06.2024 05:50:39.332	Spontaneous Com.Issued=AutoLocal
	52A4 CLOSE	ON	02.06.2024 05:50:39.326	Spontaneous
02783	AR: Auto-reclose is blocked	ON	02.06.2024 05:47:16.472	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	OFF	02.06.2024 05:47:16.471	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.06.2024 05:47:16.471	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.06.2024 05:47:16.471	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.06.2024 05:47:16.471	Spontaneous Com.Issued=AutoLocal





Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612 (9)

Number	Indication	Value	Date and time	Cause
00168	Failure: Voltage absent	OFF	02.06.2024 05:47:16.471	Spontaneous Com.Issued=AutoLocal
	52A4 CLOSE	OFF	02.06.2024 05:47:16.463	Spontaneous
02932	Synchro-check is BLOCKED	ON	02.06.2024 05:43:36.007	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.06.2024 05:43:36.007	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.06.2024 05:43:36.007	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.06.2024 05:43:36.007	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	ON	02.06.2024 05:43:36.007	Spontaneous Com.Issued=AutoLocal
	Fault Recording Start	OFF	02.06.2024 05:43:30.239	Spontaneous Com.Issued=AutoLocal
	Fault Recording Start	ON	02.06.2024 05:43:27.668	Control Issued Command Issued=DIGSI
00060	Reset LED	ON	02.06.2024 05:43:26.545	Spontaneous Com.Issued=AutoLocal
	Reset LED	ON	02.06.2024 05:43:26.545	Spontaneous Command Issued=Local
02932	Synchro-check is BLOCKED	OFF	02.06.2024 05:43:23.008	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.06.2024 05:43:23.008	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.06.2024 05:43:23.008	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.06.2024 05:43:23.008	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	OFF	02.06.2024 05:43:23.008	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	ON	02.06.2024 05:42:16.007	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.06.2024 05:42:16.007	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.06.2024 05:42:16.007	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.06.2024 05:42:16.007	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	ON	02.06.2024 05:42:16.007	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	OFF	02.06.2024 05:42:03.008	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.06.2024 05:42:03.008	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.06.2024 05:42:03.008	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.06.2024 05:42:03.008	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	OFF	02.06.2024 05:42:03.008	Spontaneous Com.Issued=AutoLocal





Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612 (11)

Number	Indication	Value	Date and time	Cause
02932	Synchro-check is BLOCKED	ON	02.06.2024 05:39:36.033	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.06.2024 05:39:36.033	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.06.2024 05:39:36.033	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.06.2024 05:39:36.033	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	ON	02.06.2024 05:39:36.033	Spontaneous Com.Issued=AutoLocal
04006	>Dis.Tele. Carrier RECEPTION Channel 1	OFF	02.06.2024 05:39:33.121	Spontaneous Com.Issued=AutoLocal
	Trip 85D	OFF	02.06.2024 05:39:33.042	Spontaneous Com.Issued=AutoLocal
	Rx 85D	OFF	02.06.2024 05:39:33.042	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	149 - OFF	02.06.2024 05:39:33.030	Spontaneous Com.Issued=AutoLocal
	Trip 85D	ON	02.06.2024 05:39:31.837	Spontaneous Com.Issued=AutoLocal
	Rx 85D	ON	02.06.2024 05:39:31.837	Spontaneous Com.Issued=AutoLocal
04006	>Dis.Tele. Carrier RECEPTION Channel 1	ON	02.06.2024 05:39:31.265	Spontaneous Com.Issued=AutoLocal
04056	Dis. Telep. Carrier SEND signal	ON	02.06.2024 05:39:31.016	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	149 - ON	02.06.2024 05:39:31.016	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	OFF	02.06.2024 05:39:30.009	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.06.2024 05:39:30.009	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.06.2024 05:39:30.009	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.06.2024 05:39:30.009	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	OFF	02.06.2024 05:39:30.009	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	ON	02.06.2024 05:37:55.032	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.06.2024 05:37:55.032	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.06.2024 05:37:55.032	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.06.2024 05:37:55.032	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	ON	02.06.2024 05:37:55.032	Spontaneous Com.Issued=AutoLocal
04006	>Dis.Tele. Carrier RECEPTION Channel 1	OFF	02.06.2024 05:37:52.127	Spontaneous Com.Issued=AutoLocal



Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612 (13)

Number	Indication	Value	Date and time	Cause
	Trip 85D	OFF	02.06.2024 05:37:52.041	Spontaneous Com.Issued=AutoLocal
	Rx 85D	OFF	02.06.2024 05:37:52.041	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	148 - OFF	02.06.2024 05:37:52.030	Spontaneous Com.Issued=AutoLocal
	Trip 85D	ON	02.06.2024 05:37:50.837	Spontaneous Com.Issued=AutoLocal
	Rx 85D	ON	02.06.2024 05:37:50.837	Spontaneous Com.Issued=AutoLocal
04006	>Dis.Tele. Carrier RECEPTION Channel 1	ON	02.06.2024 05:37:50.266	Spontaneous Com.Issued=AutoLocal
04056	Dis. Telep. Carrier SEND signal	ON	02.06.2024 05:37:50.015	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	148 - ON	02.06.2024 05:37:50.015	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	OFF	02.06.2024 05:37:49.008	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.06.2024 05:37:49.008	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.06.2024 05:37:49.008	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.06.2024 05:37:49.008	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	OFF	02.06.2024 05:37:49.008	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	ON	02.06.2024 05:36:15.048	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.06.2024 05:36:15.048	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.06.2024 05:36:15.048	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.06.2024 05:36:15.048	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	ON	02.06.2024 05:36:15.047	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	147 - OFF	02.06.2024 05:36:12.094	Spontaneous Com.Issued=AutoLocal
	Trip 85D	OFF	02.06.2024 05:36:12.044	Spontaneous Com.Issued=AutoLocal
	Rx 85D	OFF	02.06.2024 05:36:12.044	Spontaneous Com.Issued=AutoLocal
	TX 85D	OFF	02.06.2024 05:36:12.018	Spontaneous Com.Issued=AutoLocal
	Trip 85D	ON	02.06.2024 05:36:10.927	Spontaneous Com.Issued=AutoLocal
	Rx 85D	ON	02.06.2024 05:36:10.927	Spontaneous Com.Issued=AutoLocal
	TX 85D	ON	02.06.2024 05:36:10.665	Spontaneous Com.Issued=AutoLocal



Event Log - 15/02/2025 15:40:19.760 - Itahue / Folder / 7SA612_A4_15-02-2025_Var/7SA612 (15)

Number	Indication	Value	Date and time	Cause
00536	Relay Definitive TRIP	ON	02.06.2024 05:36:10.411	Spontaneous Com.Issued=AutoLocal
04056	Dis. Telep. Carrier SEND signal	ON	02.06.2024 05:36:10.240	Spontaneous Com.Issued=AutoLocal
04006	>Dis.Tele. Carrier RECEPTION Channel 1	OFF	02.06.2024 05:36:10.117	Spontaneous Com.Issued=AutoLocal
04006	>Dis.Tele. Carrier RECEPTION Channel 1	ON	02.06.2024 05:36:10.033	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	147 - ON	02.06.2024 05:36:10.012	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	OFF	02.06.2024 05:36:09.009	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	ON	02.06.2024 05:36:09.009	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	OFF	02.06.2024 05:36:09.009	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	OFF	02.06.2024 05:36:09.009	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	OFF	02.06.2024 05:36:09.009	Spontaneous Com.Issued=AutoLocal
02932	Synchro-check is BLOCKED	ON	02.06.2024 05:33:40.033	Spontaneous Com.Issued=AutoLocal
07152	Backup O/C is BLOCKED	OFF	02.06.2024 05:33:40.033	Spontaneous Com.Issued=AutoLocal
03652	Distance is BLOCKED	ON	02.06.2024 05:33:40.033	Spontaneous Com.Issued=AutoLocal
02054	Emergency mode	ON	02.06.2024 05:33:40.033	Spontaneous Com.Issued=AutoLocal
00168	Failure: Voltage absent	ON	02.06.2024 05:33:40.033	Spontaneous Com.Issued=AutoLocal
00301	Power System fault	146 - OFF	02.06.2024 05:33:37.082	Spontaneous Com.Issued=AutoLocal
	Trip 85D	OFF	02.06.2024 05:33:37.043	Spontaneous Com.Issued=AutoLocal
	Rx 85D	OFF	02.06.2024 05:33:37.043	Spontaneous Com.Issued=AutoLocal
	TX 85D	OFF	02.06.2024 05:33:37.019	Spontaneous Com.Issued=AutoLocal
	Trip 85D	ON	02.06.2024 05:33:35.938	Spontaneous Com.Issued=AutoLocal
	Rx 85D	ON	02.06.2024 05:33:35.938	Spontaneous Com.Issued=AutoLocal
	TX 85D	ON	02.06.2024 05:33:35.674	Spontaneous Com.Issued=AutoLocal
00536	Relay Definitive TRIP	ON	02.06.2024 05:33:35.420	Spontaneous Com.Issued=AutoLocal

State