

PFV_Willka_220KV_V09.30

Totally Integrated Automation Portal		
---	--	--

Table of contents

F51_FT1	3 - 1
Device information	4 - 1
Hardware and protocols	5 - 1
Measuring-points routing	6 - 1
Function-group connections	7 - 1
Settings	8 - 1

F51_FT1

F51_FT1

Author: ECOCH-HP

Creation time: 05/25/2023 14:52:08

Last modified time: 08/20/2025 22:48:09

Modified by: ECOCH_HP_CMV1

Totally Integrated Automation Portal		
--------------------------------------	--	--

F51_FT1

Device information

Device details	
Name	Value
Name	F51_FT1
IEC 61850 name	F51_FT1
IEC 61850 Edition	IEC 61850 Edition 2
Type	7SJ82
Serial number	BM2208001947
Configuration version	V08.83.04
Communication configuration version	V08.83.04
Product code	7SJ82-DAAA-AA0-0AAAA0-AL0411-12111B-BAA000-000AB0-HB1BD4-JA0
Short product code	P1J90216
CPU type	

Function points

Function-points consumption: 75 out of 175

Details		
Function	Configured instances	Total function points
25 Synchronization	1	50
27 Undervolt.-3ph	1	5
59 Overvolt.-3ph	1	5
81 Overfreq.-A	1	5
59 Overvolt.-V0	1	5
50BF Ad.CBF	1	5

Condensed information about configured protection functions.

Alimentador 1	
Name	Value
50/51 OC-3ph-A1	Settings group 1: on
50N/51N OC-gnd-A1	Settings group 1: on
27 Undervolt.-3ph 1	Settings group 1: on
59 Overvolt.-3ph 1	Settings group 1: on
81 Overfreq.-A 1	Settings group 1: on
59 Overvolt.-V0 1	Settings group 1: on

TTPP-B1	
Name	Value
No protection functions were found.	

Function-chart (CFC) statistics	
Name	Value
Ticks for task High priority Event-Triggered	268 out of 500
Ticks for task Event-Triggered	622 out of 11799
Ticks for task Low priority Event-Triggered and Low priority Cyclic-Triggered	0 out of 111976

Totally Integrated Automation Portal		
---	--	--

F51_FT1

Hardware and protocols

Binary input				
Binary input	Terminals	Module	User label	Threshold value
1.1	1D4-1D6	Base module	BI 1.1	Low: 44 V, High: 88 V
1.2	1D7-1D14	Base module	BI 1.2	Low: 44 V, High: 88 V
1.3	1D8-1D14	Base module	BI 1.3	Low: 44 V, High: 88 V
1.4	1D9-1D14	Base module	BI 1.4	Low: 44 V, High: 88 V
1.5	1D10-1D14	Base module	BI 1.5	Low: 44 V, High: 88 V
1.6	1D11-1D14	Base module	BI 1.6	Low: 44 V, High: 88 V
1.7	1D12-1D14	Base module	BI 1.7	Low: 44 V, High: 88 V
1.8	1D13-1D14	Base module	BI 1.8	Low: 44 V, High: 88 V
2.1	2L11-2L12	Base module	BI 2.1	Low: 10 V, High: 19 V
2.2	2L11-2L14	Base module	BI 2.2	Low: 44 V, High: 88 V
2.3	2L11-2L13	Base module	BI 2.3	Low: 44 V, High: 88 V
3.1	3N2-3N1	Base module	BI 3.1	Low: 10 V, High: 19 V
3.2	3N3-3N1	Base module	BI 3.2	Low: 44 V, High: 88 V
3.3	3N5-3N11	Base module	BI 3.3	Low: 44 V, High: 88 V
3.4	3N6-3N11	Base module	BI 3.4	Low: 44 V, High: 88 V
3.5	3N7-3N11	Base module	BI 3.5	Low: 44 V, High: 88 V
3.6	3N8-3N11	Base module	BI 3.6	Low: 44 V, High: 88 V
3.7	3N9-3N11	Base module	BI 3.7	Low: 44 V, High: 88 V
3.8	3N10-3N11	Base module	BI 3.8	Low: 44 V, High: 88 V
3.9	3N12-3N11	Base module	BI 3.9	Low: 44 V, High: 88 V
3.10	3N13-3N11	Base module	BI 3.10	Low: 44 V, High: 88 V
3.11	3N14-3N11	Base module	BI 3.11	Low: 44 V, High: 88 V
3.12	3N15-3N11	Base module	BI 3.12	Low: 44 V, High: 88 V

Binary output			
Binary output	Terminals	Module	User label
1.1	1B7-1B8	Base module	BO make 1.1
1.2	1B10-1B9-1B11	Base module	BO change-over 1.2
1.3	1B13-1B12-1B14	Base module	BO change-over 1.3
1.4	1D1-1D2	Base module	BO make 1.4
1.5	1D3-1D2	Base module	BO make 1.5
1.6	1D5-1D2	Base module	BO make 1.6
2.1	2L3-2L4	Base module	BO make 2.1
2.2	2L5-2L6-2L8	Base module	BO change-over 2.2
3.1	3M2-3M1	Base module	BO make 3.1
3.2	3M3-3M1	Base module	BO make 3.2
3.3	3M4-3M1	Base module	BO make 3.3
3.4	3M5-3M1	Base module	BO make 3.4
3.5	3M8-3M7	Base module	BO make 3.5
3.6	3M9-3M7	Base module	BO make 3.6
3.7	3M10-3M7	Base module	BO make 3.7

Current transformers			
Current transformer	Terminals	Module	User label
1A1	1A1-1A2	Base module	IP 1A1
1A2	1A3-1A4	Base module	IP 1A2
1A3	1A5-1A6	Base module	IP 1A3
1A4	1A7-1A8	Base module	IP 1A4

Voltage transformers			
Voltage transformer	Terminals	Module	User label
1.1	1B1-1B2	Base module	V 1.1
1.2	1B3-1B2	Base module	V 1.2
1.3	1B4-1B2	Base module	V 1.3
1.4	1B5-1B6	Base module	V 1.4

Function keys			
Function key	Module	User label	
1	Base module	Operational log	
2	Base module	Operational values	
3	Base module	Fault log	
4	Base module	Activ LR Local	
5	Base module	Activ LR Remote	
6	Base module		
7	Base module		
8	Base module		

LEDs			
LED	Module	User label	
1.1	Base module	Pickup phs A	
1.2	Base module	Pickup phs B	
1.3	Base module	Pickup phs C	

Totally Integrated Automation Portal		
--------------------------------------	--	--

LED	Module	User label
1.4	Base module	Pickup gnd
1.5	Base module	Operate general
1.6	Base module	Operate general
1.7	Base module	Operate general
1.8	Base module	Operate general
1.9	Base module	Operate general
1.10	Base module	
1.11	Base module	
1.12	Base module	
1.13	Base module	>Start
1.14	Base module	50BF_Trp_E1_FT1
1.15	Base module	50BF_Trp_E2_FT1
1.16	Base module	

Ethernet configurations

Interfaces

Slot	Module	Protocol info
J	Onboard Ethernet	Ethernet-interface settings: DCP
E	ETH-BB-2FO	Channel 1: DCP, IEC 61850-8-1, SNTP, HSR

IP Interface 1 (J\Onboard Ethernet\Channel 1): IP Interface 1

Number	Settings	Value
101.1031.5281.101	IP address	172.16.60.60
101.1031.5281.102	Subnet mask	255.255.255.0
101.1031.5281.103	Default Gateway IP Addr	0.0.0.0
101.1031.5281.104	Configuration mode	static
101.1031.5281.105	DCP enabled	on
101.1031.5281.116	ShowVLAN	false

IP Interface 1 (E\ETH-BB-2FO\Channel 1): IP Interface 1

Number	Settings	Value
102.1031.5281.101	IP address	192.168.120.143
102.1031.5281.102	Subnet mask	255.255.255.0
102.1031.5281.103	Default Gateway IP Addr	192.168.120.1
102.1031.5281.104	Configuration mode	static
102.1031.5281.105	DCP enabled	on
102.1031.5281.116	ShowVLAN	false

SNTP (E\ETH-BB-2FO\Channel 1): SNTP

Number	Settings	Value
102.1031.121.103	Time source 1	192.168.120.13
102.1031.121.104	Time source 2	192.168.120.13
102.1031.121.105	Time interval	15 s
102.1031.121.106	Start time	20 s

F51_FT1**Measuring-points routing****Current-measuring points**

Measuring point	Connection type	Terminals
TC-3PH	3-phase + IN	I A: 1A1-1A2 I B: 1A3-1A4 I C: 1A5-1A6 IN: 1A7-1A8

Voltage-measuring points

Measuring point	Connection type	Terminals
TP-3PH	3 ph-to-gnd voltages	V A: 1B1-1B2 V B: 1B3-1B2 V C: 1B4-1B2
TP-1PH		V CA: 1B5-1B6

F51_FT1

Function-group connections

Measuring point to function-group connections

Measuring point	Measuring point
TC-3PH[ID 1]	Alimentador 1:I 3ph
TC-3PH[ID 1]	Q0:I 3ph
TP-3PH[ID 2]	Alimentador 1:V 3ph
TP-3PH[ID 2]	Q0:V
TP-3PH[ID 2]	Q0:V sync1
TP-1PH[ID 4]	Q0:V sync2
TP-1PH[ID 4]	TTPP-B1:V

Function group to circuit-breaker group connections

Protection group	Circuit-breaker group(s)
Alimentador 1	Q0

Totally Integrated Automation Portal																																
F51_FT1																																
Settings																																
Device settings																																
<table border="1"> <thead> <tr> <th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>Edit mode</td><td>secondary</td></tr> <tr><td>Number settings groups</td><td>1</td></tr> <tr><td>Activat. of settings group</td><td>settings group 1</td></tr> <tr><td>DIGSI 5 uses the following interface</td><td>192.168.120.143 (Port E)</td></tr> <tr><td>Operation-panel language</td><td>English (United States)</td></tr> <tr><td>Binary input channel threshold</td><td>Low: 44 V, High: 88 V</td></tr> <tr><td>Used time stamp in GOOSE subscriptions</td><td>On message reception</td></tr> <tr><td>Hide settings in IEC 61850 structure</td><td>Show all settings</td></tr> <tr><td>Hide SIPROTEC extensions in IEC 61850 structure</td><td>Show all SIPROTEC extensions</td></tr> <tr><td>Reserv.time for com.prot.</td><td>120 s</td></tr> <tr><td>Use dynamic reporting</td><td>True</td></tr> <tr><td>Block IEC 61850 settings changes</td><td>False</td></tr> <tr><td>Access point used in Edition1</td><td>No access point is specified for the SCD import.</td></tr> <tr><td>Station name</td><td>PFV Willka (Substation name)</td></tr> </tbody> </table>			Settings	Value	Edit mode	secondary	Number settings groups	1	Activat. of settings group	settings group 1	DIGSI 5 uses the following interface	192.168.120.143 (Port E)	Operation-panel language	English (United States)	Binary input channel threshold	Low: 44 V, High: 88 V	Used time stamp in GOOSE subscriptions	On message reception	Hide settings in IEC 61850 structure	Show all settings	Hide SIPROTEC extensions in IEC 61850 structure	Show all SIPROTEC extensions	Reserv.time for com.prot.	120 s	Use dynamic reporting	True	Block IEC 61850 settings changes	False	Access point used in Edition1	No access point is specified for the SCD import.	Station name	PFV Willka (Substation name)
Settings	Value																															
Edit mode	secondary																															
Number settings groups	1																															
Activat. of settings group	settings group 1																															
DIGSI 5 uses the following interface	192.168.120.143 (Port E)																															
Operation-panel language	English (United States)																															
Binary input channel threshold	Low: 44 V, High: 88 V																															
Used time stamp in GOOSE subscriptions	On message reception																															
Hide settings in IEC 61850 structure	Show all settings																															
Hide SIPROTEC extensions in IEC 61850 structure	Show all SIPROTEC extensions																															
Reserv.time for com.prot.	120 s																															
Use dynamic reporting	True																															
Block IEC 61850 settings changes	False																															
Access point used in Edition1	No access point is specified for the SCD import.																															
Station name	PFV Willka (Substation name)																															
Activate device functionality																																
<table border="1"> <thead> <tr> <th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>Voltage variant</td><td>DC 110 V to 250 V, AC 100 V to 230 V</td></tr> <tr><td>Integrated Ethernet interface (port J)</td><td>Only DIGSI 5 connection</td></tr> <tr><td>Significant feature</td><td></td></tr> <tr><td>Select function-point class or classless</td><td>Base + 175</td></tr> </tbody> </table>			Settings	Value	Voltage variant	DC 110 V to 250 V, AC 100 V to 230 V	Integrated Ethernet interface (port J)	Only DIGSI 5 connection	Significant feature		Select function-point class or classless	Base + 175																				
Settings	Value																															
Voltage variant	DC 110 V to 250 V, AC 100 V to 230 V																															
Integrated Ethernet interface (port J)	Only DIGSI 5 connection																															
Significant feature																																
Select function-point class or classless	Base + 175																															
General \Device																																
<table border="1"> <thead> <tr> <th>Number</th><th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>91.101</td><td>Rated frequency</td><td>All: 50 Hz</td></tr> <tr><td>91.102</td><td>Minimum operate time</td><td>All: 0 s</td></tr> <tr><td>91.115</td><td>Set. format residu. comp.</td><td>All: Kr, Kx</td></tr> <tr><td>91.138</td><td>Block monitoring dir.</td><td>All: off</td></tr> <tr><td>91.164</td><td>Station name</td><td>All: PFV Willka</td></tr> </tbody> </table>			Number	Settings	Value	91.101	Rated frequency	All: 50 Hz	91.102	Minimum operate time	All: 0 s	91.115	Set. format residu. comp.	All: Kr, Kx	91.138	Block monitoring dir.	All: off	91.164	Station name	All: PFV Willka												
Number	Settings	Value																														
91.101	Rated frequency	All: 50 Hz																														
91.102	Minimum operate time	All: 0 s																														
91.115	Set. format residu. comp.	All: Kr, Kx																														
91.138	Block monitoring dir.	All: off																														
91.164	Station name	All: PFV Willka																														
General \Chatter blocking																																
<table border="1"> <thead> <tr> <th>Number</th><th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>91.123</td><td>No. permis.state changes</td><td>All: 0</td></tr> <tr><td>91.127</td><td>Initial test time</td><td>All: 1 s</td></tr> <tr><td>91.124</td><td>No. of chatter tests</td><td>All: 0</td></tr> <tr><td>91.125</td><td>Chatter idle time</td><td>All: 1 min</td></tr> <tr><td>91.137</td><td>Subsequent test time</td><td>All: 2 s</td></tr> </tbody> </table>			Number	Settings	Value	91.123	No. permis.state changes	All: 0	91.127	Initial test time	All: 1 s	91.124	No. of chatter tests	All: 0	91.125	Chatter idle time	All: 1 min	91.137	Subsequent test time	All: 2 s												
Number	Settings	Value																														
91.123	No. permis.state changes	All: 0																														
91.127	Initial test time	All: 1 s																														
91.124	No. of chatter tests	All: 0																														
91.125	Chatter idle time	All: 1 min																														
91.137	Subsequent test time	All: 2 s																														
General \Measurements																																
<table border="1"> <thead> <tr> <th>Number</th><th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>91.162</td><td>Blk setting change</td><td>Settings group 1: false</td></tr> <tr><td>91.163</td><td>Reserv.time for com.prot.</td><td>All: 120 s</td></tr> <tr><td>91.111</td><td>Energy restore interval</td><td>Settings group 1: 10 min</td></tr> <tr><td>91.112</td><td>Energy restore time</td><td>Settings group 1: none</td></tr> </tbody> </table>			Number	Settings	Value	91.162	Blk setting change	Settings group 1: false	91.163	Reserv.time for com.prot.	All: 120 s	91.111	Energy restore interval	Settings group 1: 10 min	91.112	Energy restore time	Settings group 1: none															
Number	Settings	Value																														
91.162	Blk setting change	Settings group 1: false																														
91.163	Reserv.time for com.prot.	All: 120 s																														
91.111	Energy restore interval	Settings group 1: 10 min																														
91.112	Energy restore time	Settings group 1: none																														
General \Control																																
<table border="1"> <thead> <tr> <th>Number</th><th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>91.120</td><td>Energy restore</td><td>Settings group 1: latest value</td></tr> <tr><td>91.121</td><td>Energy restore by A.time</td><td>Settings group 1: false</td></tr> <tr><td>91.118</td><td>Enable sw.auth. station</td><td>All: false</td></tr> </tbody> </table>			Number	Settings	Value	91.120	Energy restore	Settings group 1: latest value	91.121	Energy restore by A.time	Settings group 1: false	91.118	Enable sw.auth. station	All: false																		
Number	Settings	Value																														
91.120	Energy restore	Settings group 1: latest value																														
91.121	Energy restore by A.time	Settings group 1: false																														
91.118	Enable sw.auth. station	All: false																														
General \Spontan.indic.																																
<table border="1"> <thead> <tr> <th>Number</th><th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>91.119</td><td>Multiple sw.auth. levels</td><td>All: false</td></tr> </tbody> </table>			Number	Settings	Value	91.119	Multiple sw.auth. levels	All: false																								
Number	Settings	Value																														
91.119	Multiple sw.auth. levels	All: false																														
General \CFC																																
<table border="1"> <thead> <tr> <th>Number</th><th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>91.152</td><td>Specific sw. authorities</td><td>All: false</td></tr> </tbody> </table>			Number	Settings	Value	91.152	Specific sw. authorities	All: false																								
Number	Settings	Value																														
91.152	Specific sw. authorities	All: false																														
General \Test support																																
<table border="1"> <thead> <tr> <th>Number</th><th>Settings</th><th>Value</th></tr> </thead> <tbody> <tr><td>91.139</td><td>Fault-display</td><td>All: with pickup</td></tr> <tr><td>91.161</td><td>CFC chart quality handling</td><td>All: manual</td></tr> </tbody> </table>			Number	Settings	Value	91.139	Fault-display	All: with pickup	91.161	CFC chart quality handling	All: manual																					
Number	Settings	Value																														
91.139	Fault-display	All: with pickup																														
91.161	CFC chart quality handling	All: manual																														

Totally Integrated Automation Portal		
Localization		
Number	Settings	Value
6211.139	Unit system	All: SI
Time settings		
General		
Settings	Value	
Date format	All: DD.MM.YYYY	
Time source		
Settings	Value	
Fault indication after	All: 60 s	
Time source 1	Ch1:port E:SNTP	
Time source 2	none	
Time zone time source 1	All: UTC	
Time zone time source 2	All: UTC	
Sync. latency time src.1	All: 0 µs	
Sync. latency time src.2	All: 0 µs	
Time zone and daylight saving time		
Settings	Value	
Time zone offset to UTC	All: 0 min	
Offset daylight sav. time	All: 60 min	
Switch daylight sav. time	false	
Pulse per second (Port G)		
Settings	Value	
Sync. latency PPS	All: 0 µs	
Assumed SmpSynch	All: global	
Sample synchronization		
Settings	Value	
Holdover	All: Enable	
Power system \General		
General		
Number	Settings	Value
11.2311.101	Phase sequence	All: ABC
Power system \TC-3PH		
CT 3-phase \General		
Number	Settings	Value
11.931.8881.115	CT connection	All: 3-phase + IN
11.931.8881.127	Tracking	All: active
11.931.8881.130	Measuring-point ID	All: 1
CT 3-phase \CT phases		
Number	Settings	Value
11.931.8881.101	Rated primary current	All: 2500 A
11.931.8881.102	Rated secondary current	All: 1 A
11.931.8881.117	Current range	All: 50 x IR
11.931.8881.118	Internal CT type	All: CT protection
11.931.8881.116	Neutr.point in dir.of ref.obj	All: yes
11.931.8881.114	Inverted phases	All: none
CT 3-phase \MP disconnection		
Number	Settings	Value
11.931.8881.173	Current check	All: active
11.931.8881.112	< threshold	All: 0.10 A
CT 1		
Number	Settings	Value
11.931.3841.103	Magnitude correction	All: 1
11.931.3841.117	Phase	All: 1 A
CT 2		
Number	Settings	Value
11.931.3842.103	Magnitude correction	All: 1

Totally Integrated Automation Portal		
Number	Settings	Value
11.931.3842.117	Phase	All: I B
CT 3		
Number	Settings	Value
11.931.3843.103	Magnitude correction	All: 1
11.931.3843.117	Phase	All: I C
CT 4		
Number	Settings	Value
11.931.3844.103	Magnitude correction	All: 1
11.931.3844.117	Phase	All: IN
Brk.wire det.		
Number	Settings	Value
11.931.5581.1	Mode	Settings group 1: off
Supv. balan. I		
Number	Settings	Value
11.931.2491.1	Mode	Settings group 1: off
11.931.2491.101	Release threshold	Settings group 1: 0.50 A
11.931.2491.102	Threshold min/max	Settings group 1: 0.5
11.931.2491.6	Delay failure indication	Settings group 1: 5 s
Supv. ph.seq.I		
Number	Settings	Value
11.931.2551.1	Mode	Settings group 1: off
11.931.2551.6	Delay failure indication	Settings group 1: 5 s
11.931.2551.102	Release threshold	Settings group 1: 0.50 A
Supv. sum I		
Number	Settings	Value
11.931.2431.1	Mode	Settings group 1: off
11.931.2431.102	Threshold	Settings group 1: 0.10 A
11.931.2431.101	Slope factor	Settings group 1: 0.1
11.931.2431.6	Delay failure indication	Settings group 1: 5 s
Supv. ADC sum I		
Number	Settings	Value
11.931.2401.1	Mode	Settings group 1: off
Power system \TP-3PH		
VT 3-phase		
Number	Settings	Value
11.941.8911.101	Rated primary voltage	All: 33 kV
11.941.8911.102	Rated secondary voltage	All: 110 V
11.941.8911.104	VT connection	All: 3 ph-to-gnd voltages
11.941.8911.106	Inverted phases	All: none
11.941.8911.111	Tracking	All: active
11.941.8911.130	Measuring-point ID	All: 2
11.941.8911.136	Internal VT type	All: Voltage transformer
VT 1		
Number	Settings	Value
11.941.3811.103	Magnitude correction	All: 1
11.941.3811.108	Phase	All: VA
VT 2		
Number	Settings	Value
11.941.3812.103	Magnitude correction	All: 1
11.941.3812.108	Phase	All: VB
VT 3		
Number	Settings	Value
11.941.3813.103	Magnitude correction	All: 1
11.941.3813.108	Phase	All: VC

Totally Integrated Automation Portal		
Supv. balan. V		
Number	Settings	Value
11.941.2521.1	Mode	Settings group 1: off
11.941.2521.101	Release threshold	Settings group 1: 55 V
11.941.2521.102	Threshold min/max	Settings group 1: 0.75
11.941.2521.6	Delay failure indication	Settings group 1: 5 s
Supv. ph.seq.V		
Number	Settings	Value
11.941.2581.1	Mode	Settings group 1: off
11.941.2581.6	Delay failure indication	Settings group 1: 5 s
Supv. sum V		
Number	Settings	Value
11.941.2461.1	Mode	Settings group 1: off
11.941.2461.3	Threshold	Settings group 1: 27.5 V
11.941.2461.6	Delay failure indication	Settings group 1: 5 s
VT miniatureCB		
Number	Settings	Value
11.941.2641.101	Response time	Settings group 1: 0 s
Power system \TP-1PH		
General		
Number	Settings	Value
11.961.2311.101	Rated primary voltage	All: 33 kV
11.961.2311.102	Rated secondary voltage	All: 110 V
11.961.2311.103	Tracking	All: inactive
11.961.2311.130	Measuring-point ID	All: 4
VT 1		
Number	Settings	Value
11.961.3811.103	Magnitude correction	All: 1
11.961.3811.108	Phase	All: V CA
VT miniatureCB		
Number	Settings	Value
11.961.2641.101	Response time	Settings group 1: 0 s
Recording \General		
General		
Number	Settings	Value
81.2701.175	Scaling COMTRADE	All: Primary values
81.2701.176	COMTRADE revision year	All: COMTRADE 2013
81.2701.1	Mode	Settings group 1: on
Recording \Fault recorder		
Control		
Number	Settings	Value
81.791.2761.130	Fault recording	All: user-defined
81.791.2761.131	Storage	All: always
81.791.2761.111	Maximum record time	All: 3 s
81.791.2761.112	Pre-trigger time	All: 0.5 s
81.791.2761.113	Post-trigger time	All: 1 s
81.791.2761.116	Manual record time	All: 3 s
81.791.2761.140	Sampling frequency	All: 2 kHz
81.791.2761.141	Sampl. freq. IEC 61850 rec.	All: 1 kHz
81.791.2761.129	Cal.zero.seq.cur.channel	All: 3IO
81.791.2761.132	Cal.zero seq.volt.channel	All: 3V0
Alimentador 1 \General		
General \Rated values		
Number	Settings	Value
821.9451.101	Rated current	All: 2500 A
821.9451.102	Rated voltage	All: 33 kV
821.9451.103	Rated apparent power	All: 142.89 MVA

Totally Integrated Automation Portal		
--------------------------------------	--	--

General \Power-system data		
Number	Settings	Value
821.9451.149	Power-sys. neutral point	Settings group 1: grounded

General \Measurements		
Number	Settings	Value
821.9451.158	P, Q sign	Settings group 1: not reversed

Alimentador 1 \Process monitor

Alimentador 1 \Inrush detect.

Inrush detect.		
Number	Settings	Value
821.4141.1	Mode	All: on
821.4141.106	Operat.-range limit Imax	Settings group 1: 20.00 A
821.4141.111	Blocking with CWA	Settings group 1: yes
821.4141.110	Blocking with 2. harmonic	Settings group 1: yes
821.4141.102	2nd harmonic content	Settings group 1: 15 %
821.4141.112	Cross-blocking	Settings group 1: yes
821.4141.109	Cross-blocking time	Settings group 1: 0.06 s
821.4141.114	Start flt.rec	Settings group 1: yes

Alimentador 1 \50/51 OC-3ph-A1

Definite-T 1 \General		
Number	Settings	Value
821.201.661.1	Mode	Settings group 1: on
821.201.661.2	Operate & flt.rec. blocked	Settings group 1: no
821.201.661.11	1-pole operate allowed	Settings group 1: no
821.201.661.26	Dynamic settings	All: no
821.201.661.27	Blk. w. inrush curr. detect.	Settings group 1: yes
821.201.661.8	Method of measurement	Settings group 1: fundamental comp.
821.201.661.3	Threshold	Settings group 1: 1.44 A
821.201.661.4	Dropout ratio	Settings group 1: 0.95
821.201.661.102	Pickup delay	Settings group 1: 0 s
821.201.661.101	Dropout delay	Settings group 1: 0 s
821.201.661.6	Operate delay	Settings group 1: 0.5 s

ZSI \General		
Number	Settings	Value
821.201.662.1	Mode	Settings group 1: on
821.201.662.2	Operate & flt.rec. blocked	Settings group 1: no
821.201.662.11	1-pole operate allowed	Settings group 1: no
821.201.662.26	Dynamic settings	All: no
821.201.662.27	Blk. w. inrush curr. detect.	Settings group 1: yes
821.201.662.8	Method of measurement	Settings group 1: fundamental comp.
821.201.662.3	Threshold	Settings group 1: 0.92 A
821.201.662.4	Dropout ratio	Settings group 1: 0.95
821.201.662.102	Pickup delay	Settings group 1: 0 s
821.201.662.101	Dropout delay	Settings group 1: 0 s
821.201.662.6	Operate delay	Settings group 1: 0.3 s

Inverse-T 1 \General		
Number	Settings	Value
821.201.691.1	Mode	Settings group 1: on
821.201.691.2	Operate & flt.rec. blocked	Settings group 1: no
821.201.691.11	1-pole operate allowed	Settings group 1: no
821.201.691.26	Dynamic settings	All: no
821.201.691.27	Blk. w. inrush curr. detect.	Settings group 1: yes
821.201.691.8	Method of measurement	Settings group 1: fundamental comp.
821.201.691.3	Threshold	Settings group 1: 0.92 A
821.201.691.108	Pickup delay	Settings group 1: 0 s
821.201.691.130	Type of character. curve	Settings group 1: IEC normal inverse
821.201.691.113	Min. time of the curve	Settings group 1: 0 s
821.201.691.131	Reset	Settings group 1: instantaneous
821.201.691.101	Time dial	Settings group 1: 0.08
821.201.691.115	Additional time delay	Settings group 1: 0 s

Alimentador 1 \50N/51N OC-gnd-A1

General		
Number	Settings	Value
821.211.2311.9	Measured value	All: IN measured

Totally Integrated Automation Portal		
--------------------------------------	--	--

Definite-T 1 \General

Number	Settings	Value
821.211.751.1	Mode	Settings group 1: on
821.211.751.2	Operate & flt.rec. blocked	Settings group 1: no
821.211.751.26	Dynamic settings	All: no
821.211.751.27	Blk. w. inrush curr. detect.	Settings group 1: yes
821.211.751.8	Method of measurement	Settings group 1: fundamental comp.
821.211.751.3	Threshold	Settings group 1: 0.05 A
821.211.751.4	Dropout ratio	Settings group 1: 0.95
821.211.751.101	Dropout delay	Settings group 1: 0 s
821.211.751.6	Operate delay	Settings group 1: 0.5 s

ZSI \General

Number	Settings	Value
821.211.752.1	Mode	Settings group 1: on
821.211.752.2	Operate & flt.rec. blocked	Settings group 1: no
821.211.752.26	Dynamic settings	All: no
821.211.752.27	Blk. w. inrush curr. detect.	Settings group 1: yes
821.211.752.8	Method of measurement	Settings group 1: fundamental comp.
821.211.752.3	Threshold	Settings group 1: 0.05 A
821.211.752.4	Dropout ratio	Settings group 1: 0.95
821.211.752.101	Dropout delay	Settings group 1: 0 s
821.211.752.6	Operate delay	Settings group 1: 0.3 s

Inverse-T 1 \General

Number	Settings	Value
821.211.781.1	Mode	Settings group 1: off
821.211.781.2	Operate & flt.rec. blocked	Settings group 1: no
821.211.781.26	Dynamic settings	All: no
821.211.781.27	Blk. w. inrush curr. detect.	Settings group 1: no
821.211.781.8	Method of measurement	Settings group 1: fundamental comp.
821.211.781.3	Threshold	Settings group 1: 1.20 A
821.211.781.108	Type of character. curve	Settings group 1: IEC normal inverse
821.211.781.113	Min. time of the curve	Settings group 1: 0 s
821.211.781.109	Reset	Settings group 1: instantaneous
821.211.781.101	Time dial	Settings group 1: 1
821.211.781.115	Additional time delay	Settings group 1: 0 s

Alimentador 1 \27 Undervolt.-3ph 1

General

Number	Settings	Value
821.131.2311.104	Current-flow criterion	Settings group 1: on
821.131.2311.101	Threshold $>$	Settings group 1: 1.20 A
821.131.2311.103	Stabilization counter	Settings group 1: 0

Definite-T 1

Number	Settings	Value
821.131.421.1	Mode	Settings group 1: on
821.131.421.2	Operate & flt.rec. blocked	Settings group 1: no
821.131.421.10	Blk. by meas.-volt. failure	Settings group 1: yes
821.131.421.9	Measured value	Settings group 1: phase-to-phase
821.131.421.8	Method of measurement	Settings group 1: fundamental comp.
821.131.421.101	Pickup mode	Settings group 1: 1 out of 3
821.131.421.102	Pickup delay	Settings group 1: yes
821.131.421.3	Threshold	Settings group 1: 88 V
821.131.421.4	Dropout ratio	Settings group 1: 1.05
821.131.421.6	Operate delay	Settings group 1: 2 s

Definite-T 2

Number	Settings	Value
821.131.422.1	Mode	Settings group 1: off
821.131.422.2	Operate & flt.rec. blocked	Settings group 1: no
821.131.422.10	Blk. by meas.-volt. failure	Settings group 1: yes
821.131.422.9	Measured value	Settings group 1: phase-to-phase
821.131.422.8	Method of measurement	Settings group 1: fundamental comp.
821.131.422.101	Pickup mode	Settings group 1: 1 out of 3
821.131.422.102	Pickup delay	Settings group 1: no
821.131.422.3	Threshold	Settings group 1: 65.000 V
821.131.422.4	Dropout ratio	Settings group 1: 1.05
821.131.422.6	Operate delay	Settings group 1: 0.5 s

Alimentador 1 \59 Overvolt.-3ph 1

General

Number	Settings	Value
821.51.2311.101	Stabilization counter	Settings group 1: 0

Totally Integrated Automation Portal		
--------------------------------------	--	--

Definite-T 1

Number	Settings	Value
821.51.181.1	Mode	Settings group 1: on
821.51.181.2	Operate & flt.rec. blocked	Settings group 1: no
821.51.181.9	Measured value	Settings group 1: phase-to-phase
821.51.181.8	Method of measurement	Settings group 1: fundamental comp.
821.51.181.101	Pickup mode	Settings group 1: 1 out of 3
821.51.181.3	Threshold	Settings group 1: 132 V
821.51.181.4	Dropout ratio	Settings group 1: 0.95
821.51.181.6	Operate delay	Settings group 1: 2 s

Definite-T 2

Number	Settings	Value
821.51.182.1	Mode	Settings group 1: off
821.51.182.2	Operate & flt.rec. blocked	Settings group 1: no
821.51.182.9	Measured value	Settings group 1: phase-to-phase
821.51.182.8	Method of measurement	Settings group 1: fundamental comp.
821.51.182.101	Pickup mode	Settings group 1: 1 out of 3
821.51.182.3	Threshold	Settings group 1: 130.000 V
821.51.182.4	Dropout ratio	Settings group 1: 0.95
821.51.182.6	Operate delay	Settings group 1: 0.5 s

Alimentador 1 \81 Overfreq.-A 1

General		
Number	Settings	Value
821.11.2311.101	Minimum voltage	Settings group 1: 38.105 V
821.11.2311.109	Dropout differential	Settings group 1: 20 mHz

Stage 1

Number	Settings	Value
821.11.31.1	Mode	Settings group 1: on
821.11.31.2	Operate & flt.rec. blocked	Settings group 1: no
821.11.31.3	Threshold	Settings group 1: 51.6 Hz
821.11.31.6	Operate delay	Settings group 1: 0.1 s

Stage 2

Number	Settings	Value
821.11.32.1	Mode	Settings group 1: off
821.11.32.2	Operate & flt.rec. blocked	Settings group 1: no
821.11.32.3	Threshold	Settings group 1: 54 Hz
821.11.32.6	Operate delay	Settings group 1: 5 s

Alimentador 1 \Mes.v.fail.det

Mes.v.fail.det		
Number	Settings	Value
821.2671.1	Mode	Settings group 1: on
821.2671.115	Asym.fail.-DO on netw.flt.	Settings group 1: no
821.2671.113	Asym.fail. - time delay	Settings group 1: 10 s
821.2671.102	3ph.fail. - phs.curr.release	Settings group 1: 0.10 A
821.2671.103	3ph.fail. - phs.curr. jump	Settings group 1: 0.10 A
821.2671.101	3ph.fail. - VA,VB,VC <	Settings group 1: 5.000 V
821.2671.107	Switch-on 3ph. failure	All: on
821.2671.106	SO 3ph.fail. - time delay	Settings group 1: 3 s

Alimentador 1 \59 Overvolt.-V0 1

Definite-T 1		
Number	Settings	Value
821.101.331.1	Mode	Settings group 1: on
821.101.331.2	Operate & flt.rec. blocked	Settings group 1: no
821.101.331.10	Blk. by meas.-volt. failure	Settings group 1: no
821.101.331.109	Detection of faulty phase	All: no
821.101.331.8	Method of measurement	Settings group 1: fundamental comp.
821.101.331.3	Threshold	Settings group 1: 33 V
821.101.331.4	Dropout ratio	Settings group 1: 0.95
821.101.331.107	Pickup delay	Settings group 1: 0 s
821.101.331.6	Operate delay	Settings group 1: 1 s

Alimentador 1\Circuit-breaker interaction

Protection group	Circuit-breaker group(s)
Alimentador 1\ 50/51 OC-3ph-A1\ Definite-T 1	Q0:Trip, Q0:Start CB failure
Alimentador 1\ 50/51 OC-3ph-A1\ ZSI	Q0:Trip, Q0:Start CB failure
Alimentador 1\ 50/51 OC-3ph-A1\ Inverse-T 1	Q0:Trip, Q0:Start CB failure

Totally Integrated Automation Portal		
Protection group		Circuit-breaker group(s)
Alimentador 1\ 50N/51N OC-gnd-A1\ Definite-T 1		Q0:Trip, Q0:Start CB failure
Alimentador 1\ 50N/51N OC-gnd-A1\ ZSI		Q0:Trip, Q0:Start CB failure
Alimentador 1\ 27 Undervolt.-3ph 1\ Definite-T 1		Q0:Trip, Q0:Start CB failure
Alimentador 1\ 59 Overvolt.-3ph 1\ Definite-T 1		Q0:Trip, Q0:Start CB failure
Alimentador 1\ 81 Overfreq.-A 1\ Stage 1		Q0:Trip, Q0:Start CB failure
Alimentador 1\ 59 Overvolt.-VO 1\ Definite-T 1		Q0:Trip, Q0:Start CB failure

Q1 \Control

Control		
Number	Settings	Value
601.4201.101	Control model	All: SBO w. enh. security
601.4201.102	SBO time-out	All: 30 s
601.4201.103	Feedback monitoring time	All: 10 s
601.4201.104	Check switching authority	All: yes
601.4201.105	Check if pos. is reached	All: yes
601.4201.106	Check double activat. blk.	All: yes

Q1 \Disconnector

Disconnector		
Number	Settings	Value
601.5401.101	Maximum output time	All: 10 s
601.5401.102	Seal-in time	All: 0 s
601.5401.103	Switching-device type	All: disconnector

Q1-1T \Control

Control		
Number	Settings	Value
602.4201.101	Control model	All: SBO w. enh. security
602.4201.102	SBO time-out	All: 30 s
602.4201.103	Feedback monitoring time	All: 10 s
602.4201.104	Check switching authority	All: yes
602.4201.105	Check if pos. is reached	All: yes
602.4201.106	Check double activat. blk.	All: yes

Q1-1T \Disconnector

Disconnector		
Number	Settings	Value
602.5401.101	Maximum output time	All: 10 s
602.5401.102	Seal-in time	All: 0 s
602.5401.103	Switching-device type	All: disconnector

Q0 \General

General \Ref. for %-values		
Number	Settings	Value
201.2311.101	Rated normal current	All: 2500 A
201.2311.102	Rated voltage	All: 33 kV

General \Breaker settings

Number	Settings	Value
201.2311.112	Current thresh. CB open	All: 0.10 A

Q0 \Trip logic

Trip logic		
Number	Settings	Value
201.5341.103	Reset of trip command	All: with I<

Q0 \Circuit break.

Circuit break.		
Number	Settings	Value
201.4261.101	Output time	All: 0.1 s
201.4261.105	Indicat. of breaking values	All: always

Q0 \Manual close

Manual close		
Number	Settings	Value
201.6541.101	Action time	Settings group 1: 0.3 s

Totally Integrated Automation Portal		
--------------------------------------	--	--

Number	Settings	Value
201.6541.102	CB open dropout delay	Settings group 1: 0 s

Q0 \Control

Control		
Number	Settings	Value
201.4201.101	Control model	All: SBO w. enh. security
201.4201.102	SBO time-out	All: 30 s
201.4201.103	Feedback monitoring time	All: 1 s
201.4201.104	Check switching authority	All: yes
201.4201.105	Check if pos. is reached	All: yes
201.4201.106	Check double activat. blk.	All: yes
201.4201.107	Check blk. by protection	All: yes

Q0 \CB test

CB test		
Number	Settings	Value
201.6151.101	Dead time	All: 0.1 s
201.6151.102	Trip only	All: false
201.6151.103	Consider current criterion	All: false

Q0 \25 Synchronization

General		
Number	Settings	Value
201.1151.2311.127	Angle adjust. (transform.)	Settings group 1: 0 °

Synchrocheck 1 \General

Number	Settings	Value
201.1151.5071.1	Mode	Settings group 1: on
201.1151.5071.113	Continuous supervision	Settings group 1: true
201.1151.5071.101	Min. operating limit Vmin	Settings group 1: 99.000 V
201.1151.5071.102	Max. operat. limit Vmax	Settings group 1: 121 V
201.1151.5071.110	Max.durat. sync.process	Settings group 1: 30 s
201.1151.5071.108	Direct close command	Settings group 1: no
201.1151.5071.126	Voltage adjustment	Settings group 1: 1

Synchrocheck 1 \De-en.gized switch.

Number	Settings	Value
201.1151.5071.105	Close cmd. at V1< & V2>	Settings group 1: yes
201.1151.5071.106	Close cmd. at V1> & V2<	Settings group 1: yes
201.1151.5071.107	Close cmd. at V1< & V2<	Settings group 1: yes
201.1151.5071.103	V1, V2 without voltage	Settings group 1: 5.5 V
201.1151.5071.104	V1, V2 with voltage	Settings group 1: 88 V
201.1151.5071.109	Supervision time	Settings group 1: 0.1 s

Synchrocheck 1 \Synchr. conditions

Number	Settings	Value
201.1151.5071.115	Sync. operating mode	Settings group 1: on
201.1151.5071.122	Max. voltage diff. V2>V1	Settings group 1: 5.5 V
201.1151.5071.123	Max. voltage diff. V2<V1	Settings group 1: 5.5 V
201.1151.5071.117	Max. frequency diff. f2>f1	Settings group 1: 0.1 Hz
201.1151.5071.118	Max. frequency diff. f2<f1	Settings group 1: 0.1 Hz
201.1151.5071.124	Max. angle diff. α2>α1	Settings group 1: 10 °
201.1151.5071.125	Max. angle diff. α2<α1	Settings group 1: 10 °

Q0 \50BF Ad.CBF 1

50BF Ad.CBF 1		
Number	Settings	Value
201.18781.1	Mode	Settings group 1: on
201.18781.105	Holding int. start signal	Settings group 1: yes
201.18781.107	Start via binary input	All: 1 channel
201.18781.106	Holding ext. start signal	Settings group 1: no
201.18781.103	CB aux.cont. crit. allowed	Settings group 1: w. 'CB pos. closed 3p.'
201.18781.104	Dropout	Settings group 1: with effective criterion
201.18781.108	Retrip after T1	Settings group 1: parallel start T2, T1
201.18781.102	Threshold phase current	Settings group 1: 0.92 A
201.18781.101	Threshold sensitive	Settings group 1: 0.05 A
201.18781.109	Delay T1 for 3-pole retrip	Settings group 1: 0.01 s
201.18781.110	Delay T2 for 3-pole trip	Settings group 1: 0.2 s
201.18781.112	Minimum operate time	Settings group 1: 0.1 s
201.18781.120	3I0 criterion	All: Direct release
201.18781.121	I2 criterion	All: Direct release
201.18781.122	Threshold 3I0 dir. release	Settings group 1: 0.05 A

Totally Integrated Automation Portal		
--------------------------------------	--	--

Number	Settings	Value
201.18781.123	Threshold I2 dir. release	Settings group 1: 0.92 A
201.18781.124	Monit. time for BI ">Start"	Settings group 1: 15 s
201.18781.154	Immediate dropout	Settings group 1: true
201.18781.155	BI start external latch	Settings group 1: true

Q0 \74TC sup.2BI 1

74TC sup.2BI 1		
Number	Settings	Value
201.4411.1	Mode	Settings group 1: on
201.4411.100	Alarm delay	Settings group 1: 2 s

Q0 \74TC sup.2BI 2

74TC sup.2BI 2		
Number	Settings	Value
201.4412.1	Mode	Settings group 1: on
201.4412.100	Alarm delay	Settings group 1: 2 s

Q61 \Disconnector

Disconnector		
Number	Settings	Value
701.5401.101	Switching-device type	All: disconnector

Q61T \Disconnector

Disconnector		
Number	Settings	Value
702.5401.101	Switching-device type	All: disconnector

TPPP-B1 \General

General \Rated values		
Number	Settings	Value
1151.9421.102	Rated voltage	All: 33 kV

*Setting marked as favorite setting